

## Applications

- Chemical Processing Liquids
- Food Processing Liquids
- Potable Water
- Cooling Water
- Condensate Return
- Industrial Wastewater
- Mildly Corrosive Liquids
- Crude Oil & Gas
- Produced Water
- Saltwater
- CO<sub>2</sub>

### Materials and Construction

Red Thread HP pipe is manufactured by the filament winding process using continuous glass filaments saturated with aromatic amine-cured epoxy thermosetting resin. The pipe pressure rating is in accordance with API 15LR, 20 year design life at 200°F (93°C).

ASTM D-2996 Classification: RTRP-11AW1-3110

### Fittings

Fittings are manufactured with the same chemical and temperature capabilities as the pipe. Depending on the configurations and size, the fittings construction method will be compression molded, contact molded, fabricated or filament wound. Requires Red Thread/Green Thread HP 25 fittings details are in CI1360.


### Joining System

- **Bell & Spigot** - The pipe and fittings are joined using an adhesive bonded taper-taper bell and spigot connection. Pipe is supplied with one end belled (integral bell or factory-bonded coupling) and one end tapered. The pipe is available in random 12 meter (40 feet) lengths.


Epoxy adhesive available from NOV Fiber Glass Systems is used to secure the joint.

- **Flanged** - Flanged connections are available for all components and diameters.

#### View of Joint Illustrations



Bell & Spigot



Flanged

## Nominal Dimensional Data

Pipe Size		Inside Diameter		Outside Diameter <sup>(1)</sup>		Reinforced Wall Thickness		Weight		Capacity	
in	mm	in	mm	in	mm	in	mm	lbs/ft	kg/m	gal/ft	l/m
8	200	8.35	212	8.62	219	0.133	3.38	3.2	4.8	2.85	35.4
10	250	10.35	263	10.68	271	0.162	4.11	4.9	7.3	4.38	54.4
12	300	12.27	312	12.65	322	0.190	4.82	6.8	10.1	6.15	76.4
14	350	14.03	356	14.51	369	0.242	6.15	9.8	14.6	8.03	99.7
16	400	16.03	407	16.59	421	0.280	7.11	13.0	19.3	10.5	130
18	450	17.83	453	18.40	456	0.285	7.24	14.7	21.9	13.0	161
20	500	19.83	504	20.43	519	0.300	7.62	17.20	25.6	16.0	199
24	600	23.83	605	24.55	624	0.360	9.14	24.8	36.9	23.2	288

## Supports

The following engineering analysis must be performed to determine the maximum support spacing for the piping system. Proper pipe support spacing depends on the temperature and weight of the fluid carried in the pipe. The support spacing is calculated using continuous beam equations and the pipe bending modulus derived from long-term beam bending tests. The following tables were developed to ensure a design that limits beam mid-span deflection to 1/2 inch and bending stresses to less than or equal to 1/8 of the ultimate bending stress. Any additional weight on the piping system such as insulation or heat tracing requires further consideration. Restrained (anchored) piping systems operating at elevated temperatures often result in guide spacing requirements that are more stringent than simple unrestrained piping systems. In this case, the maximum guide spacing will dictate the support/guide spacing requirements for the system. Pipe support spans at changes in direction require special attention. Supported and unsupported fittings, at changes in direction are considered in the following tables and must be followed to properly design the piping system.

## Support Spacing vs. Specific Gravity

<b>Specific Gravity</b>	2.00	1.50	1.25	1.00	0.75
<b>Multiplier</b>	0.85	0.91	0.95	1.00	1.06

Example: Assuming a continuous span of 35.2 feet then with a 1.5 specific gravity fluid the maximum support spacing = 35.2 x 0.91 = 32.0 ft. (9.76 m)

## Maximum Support Spacing for Uninsulated Pipe<sup>(1)</sup>

Size		Continuous Spans of Pipe <sup>(2)</sup>			
		feet		meters	
in	mm	75°F	200°F	24°C	93°C
8	200	24.21	17.55	7.38	5.35
10	250	26.83	19.45	8.18	5.93
12	300	19.13	21.12	8.88	6.44
14	350	31.95	23.16	9.74	7.06
16	400	34.24	24.82	10.44	7.57
18	450	35.38	25.65	10.78	7.82
20	500	36.84	26.71	11.23	8.14
24	600	40.38	29.27	12.31	8.92

<sup>(1)</sup> For Sg=1.0, consult manufacturer for heavier insulated pipe support spans. Span recommendations include no provision for weight of (fittings, valves, etc.) or thrusts at branches and turns. Heavy valves and other appurtenances must be supported separately.

<sup>(2)</sup> Calculated spans are based on 1/2" mid-span deflections to ensure good appearance and adequate drainage. Total system stresses should always be taken into account by the system design engineer when determining support spans.


There are seven basic rules to follow when designing piping system supports, anchors, and guides:

1. Do not exceed the recommended support span.
2. Support valves and heavy in-line equipment independently.  
This applies to both vertical and horizontal piping.
3. Protect pipe from external abrasion.
4. Avoid point contact loads
5. Avoid excessive bending. This applies to handling, transporting, initial layout, and final installed position.
6. Avoid excessive vertical run loading. Vertical loads should be supported sufficiently to minimize bending stresses at outlets or changes in direction.
7. Provide adequate axial and lateral restraint to ensure line stability during rapid changes in flow.

### Adjustment Factors for Various Spans With Unsupported Fitting at Change in Direction


Span Type	Factor	
Lc	Continuous interior or fixed end spans	1.00
C	Second span from supported end or unsupported fitting	0.80
A+B	Sum of unsupported spans at fitting	≤0.75*
D	Simple supported end span	0.67

\*For example: If continuous support is 10 ft. (3.04 m), A+B must not exceed 7.5 ft.(2.28 m) (A=3 ft. (0.91 m) and B=4.5 ft. (1.37 m)) would satisfy this condition.



### Adjustment Factors for Various Spans With Supported Fitting at Change in Direction

Span Type	Factor	
Lc	Continuous interior or fixed end spans	1.00
A	Second span from simple supported end or unsupported fitting	0.80
B	Simple supported end span	0.67



### Thermal Expansion

The effects of thermal gradients on piping systems may be significant and should be considered in every piping system stress analysis. Pipe line movements due to thermal expansion or contraction may cause

high stresses or even buckle a pipe line if improperly restrained. Several piping system designs are used to manage thermal expansion and contraction in above ground piping systems. They are listed below according to economic preference:

1. Use of inherent flexibility in directional changes.
2. Restraining axial movements and guiding to prevent buckling.
3. Use expansion loops to absorb thermal movements.
4. Use mechanical expansion joints to absorb thermal movements.

To perform a thermal analysis the following information is required:

1. Isometric layout of piping system
2. Physical and material properties of pipe
3. Design temperatures
4. Installation temperature (Final tie in temperature)
5. Terminal equipment load limits
6. Support movements

A comprehensive review of temperature effects on fiberglass pipe may be found in NOV Fiber Glass Systems’ Engineering and Piping Design Guide, Section 3.

Change in Temperature		Pipe Change in Length	
°F	°C	in/100 ft	cm/100 m
25	13.9	0.32	2.67
50	27.8	0.64	5.35
75	41.7	0.96	8.02
100	55.6	1.28	10.7

### Testing

Hydrostatic testing is recommended to evaluate the integrity of all new piping installations. For systems operating below the system rating, a test pressure of 1.5 times the system operating pressure is recommended; however, the maximum test pressure must not exceed 1.5 times the lowest pressure rated fiberglass component in the piping system.

The hydro test pressure should be repeated up to ten cycles from 0 psig to the test pressure to provide a high degree of confidence in the piping system. The final pressurization cycle should be allowed to stabilize for 15-30 minutes, then inspected for leaks. Do not attempt to repair leaks while system is pressurized. The hydro test should be repeated after any re-work is performed.

When hydro testing, open high-point vents (if used) to prevent entrapment of air in the lines as the system is slowly filled with water, then close the vents and slowly pressurize to the test pressure. Upon completion of hydro test, relieve the pressure on the system slowly, open vents and any drains to allow for complete drainage of the system.

### Water Hammer

Piping systems may be damaged by pressure surges due to water hammer. The use of soft start pumps and slow actuating valves will reduce the magnitude of surge pressures during operation and are highly recommended.

## Typical Mechanical Properties

Pipe Property	75°F	24°C	200°F	93°C	Method
	psi	MPa	psi	MPa	
<b>Axial Tensile</b>					
Ultimate Stress	9,530	65.7	6,585	45.4	ASTM D2105
Modulus of Elasticity	1.68 x 10 <sup>6</sup>	11,584	1.42 x 10 <sup>6</sup>	9,791	ASTM D2105
<b>Poisson's Ratio, <math>\nu_{ah}</math> (<math>\nu_{ha}</math>)<sup>(1)</sup></b>	0.35 (0.61)				
<b>Axial Compression</b>					
Ultimate Stress	12,510	86.3	8,560	59.0	ASTM D695
Modulus of Elasticity	0.677 x 10 <sup>6</sup>	4,668	0.379 x 10 <sup>6</sup>	2,613	ASTM D695
<b>Beam Bending</b>					
Modulus of Elasticity (Long Term)	2.6 x 10 <sup>6</sup>	17,927	0.718 x 10 <sup>6</sup>	4,951	ASTM D2925
<b>Hydrostatic Burst</b>					
Ultimate Hoop Tensile Stress	40,150	277	36,480	252	ASTM D1599
<b>Hydrostatic Hoop Design Stress</b>					
Static 20 Year Life	LTHS - 95% LCL	-	18,203 - 14,689	125.5 - 101.3	ASTM D2992 - Procedure B
Static 50 Year Life	LTHS - 95% LCL	-	16,788 - 13,142	115.7 - 90.6	ASTM D2992 - Procedure B
<b>Parallel Plate</b>					
Hoop Modulus of Elasticity	3.02 x 10 <sup>6</sup>	20,822	-	-	ASTM D2412
<b>Shear Modulus</b>	1.36 x 10 <sup>6</sup>	9,343	1.15 x 10 <sup>6</sup>	7,895	-
	1.76 x 10 <sup>6</sup>	12,135	1.63 x 10 <sup>6</sup>	11,239	[Shear Modulus Updates 12 7 2017]

## Typical Physical Properties

Pipe Property	Value	Value	Method
Thermal Conductivity	0.23 BTU/hr•ft•°F	0.4 W/m°C	ASTM D177
Thermal Expansion	10.7 x 10 <sup>-6</sup> in/in/°F	19.3 x 10 <sup>-6</sup> mm/mm/°C	ASTM D696
Absolute Roughness	0.00021 in	0.00053 mm	
Specific Gravity	1.8		ASTM D792

## Ultimate Collapse Pressure

Size		Collapse Pressure <sup>(2,3,4)</sup>			
		psig		MPa	
In	mm	75°F	200°F	24°C	93°C
8	200	35	25	0.241	0.172
10	250	32	23	0.221	0.159
12	300	31	22	0.214	0.152
14	350	48	35	0.331	0.241
16	400	51	37	0.352	0.255
18	450	35	26	0.241	0.179
20	500	28	20	0.193	0.138
24	600	28	20	0.193	0.138

<sup>(1)</sup>  $\nu_{ha}$  = The ratio of axial strain to hoop strain resulting from stress in the hoop direction.

$\nu_{ah}$  = The ratio of hoop strain to axial strain resulting from stress in the axial direction.

<sup>(2)</sup> The differential pressure between internal and external pressure which causes collapse.

<sup>(3)</sup> A 0.67 design factor is recommended for short duration vacuum service. A full vacuum is equal to 14.7 psig (0.101 MPa) differential pressure at sea level.

<sup>(4)</sup> A 0.33 design factor is recommended for sustained (long-term) differential collapse pressure design and operation.

National Oilwell Varco has produced this brochure for general information only, and it is not intended for design purposes. Although every effort has been made to maintain the accuracy and reliability of its contents, National Oilwell Varco in no way assumes responsibility for liability for any loss, damage or injury resulting from the use of information and data herein nor is any warranty expressed or implied. Always cross-reference the bulletin date with the most current version listed at the web site noted in this literature.

### Fiber Glass Systems

17115 San Pedro Avenue, Ste 200  
San Antonio, Texas 78232 USA  
Phone: 210 477 7500  
Fax: 210 477 7560